



ALL INDIA INSTITUTE OF MEDICAL SCIENCES, BATHINDA

ਅਖਿਲ ਭਾਰਤੀ ਆਯੁਰ ਵਿਗਿਆਨ ਸੰਸਥਾਨ, ਬਠਿੰਡਾ | ਅਖਿਲ ਭਾਰਤੀ ਆਯੁਰਵਿਗਿਆਨ ਸੰਸਥਾਨ, ਬਠਿੰਡਾ
(A Central Autonomous Body under the Ministry of Health and Family Welfare, New Delhi)

DEPARTMENT OF ENGINEERING & ESTATE OFFICE



No. AIIMS Bathinda/Engg. & Estate/24-25/1939

Dated 08 July 2024

**CALL FOR QUOTATIONS FROM PROSPECTIVE FIRMS FOR PURCHASE OF
WATER COOLER (Qty. 01 Nos.)**

1. In compliance of the Office Order No. AIIMS/BTI/Engg. & Estate/OO/1929 dated 04 July 2024, there is a need to publish the quotation document for purchase of water cooler on the Institute Website. The last date of submission of quotation shall be **19th July 2024 (Friday), 17:00 hrs.** at Department of Engineering & Estate, C Block, 2nd Floor, Medical College, AIIMS Bathinda-151001.

2. The specifications of the purchase is attached. The quotation shall be submitted in a sealed envelope duly stamped & signed and **“Quotation document for purchase of Water Cooler, AIIMS Bathinda – Dept. of Engineering & Estate”** should be superscribed on the envelopes.

-Sd-
Members of the Committee

Minimum Required Specifications of Water Cooler in ESS-1 & HVAC Plant room (for procurement)

SR No.	Generic		Capacity		Rating		Material		Certification	
1	Description	Drinking Water Cooler, Storage Type	Cooling Capacity (in liters/ hour)	40	Input Voltage	230/240, 50Hz, AC, Single Phase	Material of Drinking Water Cooler Body	Fully Stainless Steel with more than 0.5mm thickness	Minimum warranty on machine (in years)	1
2	ISI Marked	Yes	Storage Capacity (in liters)	80	Maximum Energy Consumption (in watts)	550 to 600	Material of Drinking Water Cooler storage tank sheet	Stainless Steel grade 304 with 0.5mm thickness	Minimum warranty on compressor(in years)	1
3	---	---	---	---	Minimum Power factor	0.85 to 1.0	Material of Water Cooler cover lid	Epoxy painted Galvanized Iron sheet	Availability of type test reports from Central Govt. Lab/NABL credited lab/ILAC credited lab	Yes as per IS:1475:2001 latest
4	---	---	---	---	Connecting Cable	1.5m to 2.0m length of 3 core cable conforming to IS:9968 or IS:694 provided	Material of Water Cooler bottom sheet	Epoxy painted Galvanized Iron sheet	Test report number and date	Must Declare
5	---	---	---	---	---	---	Eco-Friendly refrigerant (NON CFC)	Yes	Agreed to furnish all the test reports and certification to buyer on demand at anytime before or after installation of water cooler	Yes